

- 1. FLOW MAY BE IN EITHER DIRECTION
- 2. VALVE SHAFT WILL MEET OR EXCEED AWWA C504 REQUIREMENTS
- 3. REFERENCE AWWA C504 FOR FLANGES AND DRILLING (ANSI 125)
- 4. 48 TURNS TO CLOSE
- 5. (16) 1 1/8" BOLTS ON EACH FLANGE (4 THREADED HOLES. 1 1/8"-7 UNC, THREADED THRU)
- 6. OPERATED BY 18" HANDWHEEL
- 7. RATED FOR 150PSI WORKING PRESSURE


WRITTEN CONSENT. DESIGN AND INVENTION RIGHTS RESERVED.



## M&H VALVE COMPANY

A DIVISION OF MCWANE INC. P.O. BOX 2088 ANNISTON, ALABAMA 36202 **DRAWN:** CTJ **DATE:** 11/2/2020 **DWG. NO.**BD18-F11-M2210-11110

18" AWWA C504 BUTTERFLY VALVE FLANGED ENDS - CL150 HANDWHEEL OPERATOR - OPEN LEFT FA16 OPERATOR FLANGE



## NOTES:

1. (\*) SEAL PLATE PROVIDED WITH ALL BARESTEM VALVES, AND USED WITH ALL PURCHASED OPERATORS

ITEM	DESCRIPTION	MATERIAL
1	OPERATOR SHAFT	304 STAINLESS STEEL, ASTM A-276
2	V-RING PACKING	EPDM & BUNA-N
3	BUTTERFLY VALVE BODY	DUCTILE IRON, ASTM A-536
4	UPPER JOURNAL BEARING	NYLATRON
5	VANE RING HEXHEAD CAP SCREWS	18-8 STAINLESS STEEL
6	THRUST SHAFT	304 STAINLESS STEEL, ASTM A-276
7	LOWER JOURNAL BEARING	NYLATRON
8	THRUST BEARING	BRONZE ALLOY
9	BODY END PLUG	STEEL
10	BODY END PLUG O-RING	EPDM
11	THRUST BEARING CAP SCREW	18-8 STAINLESS STEEL
12	BODY O-RING	EPDM
13	BODY SEAT RING	316 STAINLESS STEEL
14	VANE SEAT RING	EPDM W/ STAINLESS STEEL INSERT
15	VANE	DUCTILE IRON, ASTM A-536
16	VANE SHAFT TORGE PLUG	18-8 STAINLESS STEEL
17	SEAL PLATE *	STEEL

THIS DWG. AND ALL INFORMATION IS OUR PROPERTY AND SHALL NOT BE USED, COPIED, OR REPRODUCED WITHOUT



## **M&H VALVE COMPANY**

A DIVISION OF MCWANE INC. P.O. BOX 2088 ANNISTON, ALABAMA 36202 DRAWN: CTJ
DATE: 10/26/2020
DWG. NO.
BB18-F11-B0000-11110

18" AWWA C504 BUTTERFLY VALVE FLANGED ENDS - CL150 BODY SUB-ASM MATERIAL LIST FA16 OPERATOR FLANGE