

- 1. FLOW MAY BE IN EITHER DIRECTION
- 2. VALVE SHAFT WILL MEET OR EXCEED AWWA C504 REQUIREMENTS
- 3. REFERENCE AWWA C504 FOR FLANGES AND DRILLING (ANSI 125)
- 4. 90° TO CLOSE
- 5. (8) 5/8" BOLTS ON EACH FLANGE (NO THREADED HOLES)
- 6. OPERATED BY 10 POSITION LEVER OPERATOR
- 7. RATED FOR 150PSI WORKING PRESSURE

THIS DWG. AND ALL INFORMATION IS OUR PROPERTY AND SHALL NOT BE USED, COPIED, OR REPRODUCED WITHOUT WRITTEN CONSENT. DESIGN AND INVENTION RIGHTS RESERVED.



M&H VALVE COMPANY


A DIVISION OF MCWANE INC. P.O. BOX 2088 ANNISTON, ALABAMA 36202 DRAWN: CTJ

DATE: 9/30/2020

DWG. NO.

BD04-F11-L0000-11110

4" AWWA C504 BUTTERFLY VALVE FLANGED ENDS - CL150 LEVER OPERATED FA12 OPERATOR FLANGE



NOTES:

 (*) SEAL PLATE PROVIDED WITH ALL BARESTEM VALVES, AND USED WITH ALL PURCHASED OPERATORS

ITEM	DESCRIPTION	MATERIAL
1	OPERATOR SHAFT	304 STAINLESS STEEL, ASTM A-276
2	V-RING PACKING	EPDM & BUNA-N
3	BUTTERFLY VALVE BODY	DUCTILE IRON, ASTM A-536
4	UPPER JOURNAL BEARING	NYLATRON
5	VANE RING HEXHEAD CAP SCREWS	18-8 STAINLESS STEEL
6	LOWER JOURNAL BEARING	NYLATRON
7	BODY END PLUG	STEEL
8	BODY O-RING	EPDM
9	BODY SEAT RING	316 STAINLESS STEEL
10	VANE SEAT RING	EPDM W/ STAINLESS STEEL INSERT
11	VANE SHAFT TORGE PLUG	18-8 STAINLESS STEEL
12	VANE	DUCTILE IRON, ASTM A-536
13	SEAL PLATE *	STEEL
11	VANE SHAFT TORGE PLUG VANE	18-8 STAINLESS STEEL DUCTILE IRON, ASTM A-536



M&H VALVE COMPANY

A DIVISION OF MCWANE INC. P.O. BOX 2088 ANNISTON, ALABAMA 36202 DRAWN: CTJ
DATE: 9/30/2020
DWG. NO.
BB04-F11-B0000-11110

4" AWWA C504 BUTTERFLY VALVE FLANGED ENDS - CL150 BODY SUB-ASM MATERIAL LIST FA12 OPERATOR FLANGE